



**CERT**

# DVGW type examination certificate

## DVGW-Baumusterprüfzertifikat

**DV-7301CS0089**

Registration Number  
Registriernummer

<b>Field of Application</b> <i>Anwendungsbereich</i>	products of gas and water supply <i>Produkte der Gas- und Wasserversorgung</i>
<b>Owner of Certificate</b> <i>Zertifikatinhaber</i>	C.P.C. INOX S.p.A Via Senofonte 4, I-20145 Milano
<b>Distributor</b> <i>Vertreiber</i>	C.P.C. INOX S.p.A Via Senofonte 4, I-20145 Milano
<b>Product Category</b> <i>Produktart</i>	stainless tubes: stainless steel tube (7301)
<b>Product Description</b> <i>Produktbezeichnung</i>	tube made of stainless steel (material: 1.4404)
<b>Model</b> <i>Modell</i>	Edelstahlrohr "CPC INOX"
<b>Test Reports</b> <i>Prüfberichte</i>	laboratory control test: 1110192-001 from 01.04.2021 (TTR) supplement test: 20210324 from 24.03.2021 (TTR) supplement test: 20200626 from 26.06.2020 (TTR) supplement test: 20200313 from 13.03.2020 (TTR) supplement test: 20191125 from 07.11.2019 (TTR) type testing: 20170401 from 01.04.2017 (TTR)
<b>Test Basis</b> <i>Prüfgrundlagen</i>	DVGW GW 541 (01.10.2004) UBA BWGL-Metalle (14.05.2020)
<b>Date of Expiry / File No.</b> <i>Ablaufdatum / Aktenzeichen</i>	01.04.2027 / 22-0232-WNV

70029 04-A DE

21.04.2022 LE A-1/2

Date, Issued by, Sheet, Head of Certification Body  
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



Deutsche  
Akkreditierungsstelle  
D-ZE-16028-01-05

DVGW CERT GmbH  
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3  
53123 Bonn

Tel. +49 228 91 88 - 888  
Fax +49 228 91 88 - 993

www.dvgw-cert.com  
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
Edelstahlrohr "CPC INOX"	manufacturing group: 18,0 up to 76,0 mm	according to GW 541, table 3

**certified Components***zertifizierte Bauteile / Werkstoffe*

Registr. No. <i>Registr.-Nr.</i>	Component <i>Bauteil (Produktart)</i>	Model/Type <i>Modell/Typ</i>	Manufacturer <i>Hersteller</i>
HW-1001DM0302	Metal components, product group P1	1.4404 / CPC INOX/Edelstahlrohr 1.4404	C.P.C. INOX S.p.A

**Hints of Utilization / Remarks***Verwendungshinweise / Bemerkungen*

tested diameters (GW 541, table 3):

18,0 x 1,0 mm, 22,0 x 1,2 mm, 28,0 x 1,2 mm, 35,0 x 1,5 mm, 42,0 x 1,5 mm, 54,0 x 1,5 mm and 76,1 x 2,0 mm